



	Water Demand		Wastewater Discharge		Properties Included
	Peak Day GPD	Annual GPY	Peak Day GPD	Annual GPY	
2026	234,000	2,814,000	81,000	2,031,000	Area 3B
Future (TBD)	702,000	8,442,000	243,000	6,093,000	Area 3B, Area 3A, Area 2

Notes:

- Demands do not include fire water.
- Demands include multiple datacenter projects across all MSFT owned campuses.
- Peak day demands occur on a select few days per year. Total annual cooling hours per year are appoximately 480 hours.
- Demands are projections based on current planning and are subject to change.